



NOTES:

1. GATE TO BE AT END OF ENCLOSURE.
2. WHERE TWO BACKFLOW PREVENTION DEVICE (BPD'S) ARE INSTALLED PARALLEL, ENCLOSURE SHALL PROVIDE FOR MIN. CLEARANCES SHOWN ON B-4-1, PROVIDE DOUBLE GATE WITH DOUBLE DROP ROD FOR LATCHING.
3. ALL ENCLOSURES SHALL BE MILD STEEL BFE-62M, AND SHALL BE SECURED IN SUCH A MANNER AS TO PREVENT TAMPERING OR UNAUTHORIZED ENTRY.
4. CONCRETE PAD TO BE 520-C-2500 PCC, TOP OF PAD, SHALL SLOPE TO EDGE AND SET 2" MINIMUM ABOVE EXISTING SOIL LEVEL.
5. MEDIUM BROOM FINISH ON CONCRETE PAD.
6. ALTERNATIVE ENCLOSURE MAY BE INSTALLED WITH APPROVAL BY THE CITY ENGINEER.
7. ENCLOSURES REQUIRED ON ALL BACKFLOW PREVENTION DEVICE (BPD'S) GREATER THAN 2"Ø.

TITLE: **BACKFLOW PREVENTION DEVICE ENCLOSURE FOR FIRE PROTECTION SYSTEM**

DRAWN BY: LOUIE C. GUEVARA	SCALE: NONE
REVIEWED BY: DAVID RUBCIC	REVISED: SEPTEMBER, 2013

APPROVED:



9-20-13

STANDARD PLAN

B-4-3

CITY OF HOLLISTER
ENGINEERING DEPARTMENT

CITY ENGINEER: RUDI GOLNIK LIC. NO. 39570 EXP. DATE: 12-31-2013

DATE

SHEET 3 OF 3