



NOTES:

1. STEEL ENCLOSURES " PIPELINE PRODUCTS ZINC & COLOR VC-330 #10 GAUGE STEEL, 30" DIA. X 36" TALL ENCLOSURE. TALL ENCLOSURE, COLOR SHALL BE GREEN.
2. PROVIDE HINGE WITH LATCH FOR PAD LOCK, SUPPLY (2) TWO KEYS TO UTILITY DEPARTMENT.
3. PAINT CAGE AND DOOR, BOTH INSIDE AND OUTSIDE, WITH (2) TWO COATS OF RUSTOLEUM MEDIUM GREEN OR EQUAL, GREEN ENAMEL, GREEN POWDER COATED.
4. INSTALL INSULATED STRANDED WIRE GAGE #10 ON TOP OF THE POLYEHYLENE TUBING.
5. AIR VAC TO BE LOCATED AT THE HIGHEST POINT IN THE LINE AND WHERE FEASIBLE AT THE PROPERTY LINE OR LOCATIONS APPROVED BY CITY PUBLIC WORKS INSPECTOR.
6. AIR & VACUUM RELIEF VALVE SHALL BE (APCO NO. 50 OR APPROVED EQUAL) 1/2" FOR 3" TO 6" SERVICES AND 3/4" FOR 8" TO 12" SERVICES.

TITLE:
AIR AND VACUUM COMBINATION RELEASE VALVE ASSEMBLY (ABOVE GRADE)

DRAWN BY: LOUIE C. GUEVARA	SCALE: NONE	APPROVED: 	STANDARD PLAN
REVIEWED BY: DAVID RUBCIC	REVISED: SEPTEMBER, 2013	DATE: 9-20-13	B-6
CITY OF HOLLISTER ENGINEERING DEPARTMENT		CITY ENGINEER: RUDI GOLNIK LIC. NO. 39570 EXP. DATE: 12-31-2013	SHEET 1 OF 1