



NOTES:

1. ALL THRUST BLOCKS TO BE INSTALLED ACCORDING TO THESE DETAILS UNLESS OTHERWISE NOTED OR DETAILED.
2. THE PORTLAND CEMENT CONCRETE USED FOR THRUST BLOCKS SHALL BE 450-C-2000 PCC.
3. ALL ANCHOR RODS SHALL BE GALVANIZED STEEL, MINIMUM 1/2" DIAMETER, WRAPPED AROUND PIPE.
4. FLOW DIRECTION INDICATED BY →
5. ALL VIEWS ARE PLAN VIEW UNLESS OTHERWISE SHOWN.
6. WRAP ALL PVC TEES AND ELBOWS PRIOR TO PLACEMENT OF CONCRETE THRUST BLOCK.
7. MIN. 1-SQUIRE FOOT BEARING AREA FOR ALL THRUST BLOCKS.

TITLE: **IRRIGATION - 3"Ø PVC PIPE THRUST BLOCK SCHEDULE**

DRAWN BY: LOUIE C. GUEVARA	SCALE: NONE
REVIEWED BY: DAVID RUBCIC	REVISED: OCTOBER, 2013

APPROVED:



12-20-13
DATE

CITY ENGINEER: DAVID RUBCIC LIC. NO. 57601 EXP. DATE: 12-31-2013

STANDARD PLAN

G-2

SHEET 1 OF 1

CITY OF HOLLISTER
ENGINEERING DEPARTMENT