



NOTES:

1. STEEL ENCLOSURE TO BE "PIPELINE PRODUCTS ZINC & COLOR VC-330 #10 GAUGE STEEL, 30" DIA. X 36" TALL. COLOR SHALL BE GREEN.
2. PROVIDE HINGE WITH LATCH FOR PAD LOCK, SUPPLY (2) TWO KEYS TO UTILITY DEPARTMENT.
3. PAINT CAGE AND DOOR, BOTH INSIDE AND OUTSIDE, WITH (2) TWO COATS OF RUSTOLEUM MEDIUM GREEN OR EQUAL, GREEN ENAMEL.
4. INSTALL INSULATED STRANDED WIRE GAGE #10 ON TOP OF THE POLYEHYLENE TUBING.
5. AIR VAC TO BE LOCATED AT THE HIGHEST POINT IN THE LINE AND, WHERE FEASIBLE, AT THE PROPERTY LINE OR LOCATIONS APPROVED BY CITY PUBLIC WORKS INSPECTOR.
6. AIR & VACUUM RELIEF VALVE SHALL BE (APCO NO. 50 OR APPROVED EQUAL) 1/2" FOR 3" TO 6" SERVICES AND 3/4" FOR 8" TO 12" SERVICES.

TITLE:
AIR AND VACUUM COMBINATION RELEASE VALVE ASSEMBLY (ABOVE GRADE)

DRAWN BY: STAFF	SCALE: NONE
REVIEWED BY: DANNY HILLSTOCK	REVISED: OCTOBER, 2019

APPROVED:

Danny Hillstock

CITY ENGINEER: DANNY HILLSTOCK, LIC. NO. 70647

11-5-19
DATE

STANDARD PLAN

B-6

SHEET 1 OF 1

CITY OF HOLLISTER
 ENGINEERING DEPARTMENT