



TYPICAL SECTION A-A

NOTES:

1. SHALLOW FLAT TOP COVER MAYBE USED WITH AGENCY ENGINEER APPROVAL.
2. DROP MANHOLE DETAIL SEE STANDARD PLAN C-1-3.
3. CONCENTRIC CONE MAY BE USED WITH AGENCY ENGINEER APPROVAL.
4. AN IMPRESSION RING SHALL BE USED PRIOR TO INSTALLING THE FIRST RISER SECTION PRECUT UNIT SHALL BE ASSEMBLED USING PERFORMED JOINT SEALING COMPOUND OR CLASS "B" MORTAR AND ALL JOINTS SHALL BE FINISHED.
5. MANHOLES IN UNPAVED AREA SHALL REQUIRE A 5' X 5' CONCRETE PAD.
6. CAST IN PLACE MANHOLES SHALL BE 2500 PSI CONCRETE MINIMUM.
7. PRECAST MANHOLES SHALL BE 3250 PSI CONCRETE MINIMUM.

TITLE: TYPE 1 STANDARD MANHOLE PIPE 6" TO 18"

DRAWN BY: STAFF
 SCALE: NONE
 REVIEWED BY: DANNY HILLSTOCK
 REVISED: OCTOBER, 2019

APPROVED: *Danny Hillstock* 11-5-19
 CITY ENGINEER: DANNY HILLSTOCK LIC. NO. 70647
 DATE

STANDARD PLAN
C-1-1
 SHEET 1 OF 4

CITY OF HOLLISTER
 ENGINEERING DEPARTMENT