



NOTES:

1. MANHOLE BASE SHALL BE CLASS 560-B-3250 PCC.
2. PRECAST CONCRETE BARREL, ADJUSTMENT RING & TAPERED SECTIONS SHALL CONFORM TO CLASS III R.C.P. (ASTM C76).
3. CUT ALL EXCESS RAMNECK JOINT SEALANT. INTERIOR JOINTS SHALL BE SMOOTHLY FINISHED WITH MORTAR.
4. USE STANDARD PLAN C-1-4 FOR STANDARD MANHOLE FRAME/COVER AND CONCRETE COLLAR.
5. BARREL SECTION CAN BE PLACED AFTER THREE (3) DAYS OF CONCRETE BASE PLACEMENT, OR AS APPROVED BY CITY ENGINEER.
6. CONCRETE SAMPLING REQUIRED AS DETERMINED BY THE CITY ENGINEER OR PUBLIC WORKS INSPECTOR.

TITLE: TYPE II STANDARD MANHOLE (PIPE 18" TO 42 INCHES)

DRAWN BY: STAFF	SCALE: NONE
REVIEWED BY: DANNY HILLSTOCK	REVISED: OCTOBER, 2019
CITY OF HOLLISTER ENGINEERING DEPARTMENT	

APPROVED: <i>Danny Hillstock</i> CITY ENGINEER: DANNY HILLSTOCK, LLC, NO. 70647	DATE: 11-5-19
---	------------------

STANDARD PLAN D-2-1 SHEET 1 OF 2
