



**NOTES:**

1. ALL CONCRETE SHALL BE 560-B-3250 PCC PRECAST INLETS.
2. CAST-IN-PLACE INLET BASE SHALL BE PLACED AGAINST UNDISTURBED EARTH.
3. NO CONCRETE SHALL BE PLACED PRIOR TO APPROVAL BY THE CITY ENGINEER, OR PUBLIC WORKS INSPECTOR.
4. PIPES MAY BE PLACED IN ANY WALL AND GROUTED IN-PLACE.
5. REINFORCING BARS SHALL BE REQUIRED IN WALLS WHICH ARE MORE THAN 6' DEEP. FROM TOP OF CURB HORIZONTAL AND VERTICAL BARS SHALL BE #4, SPACE 12" O.C. AND PLACED AT 2" CLEAR OF INSIDE WALL SURFACE.
6. PRECAST INLETS ARE SUBJECT TO WRITTEN APPROVAL OF THE CITY ENGINEER, EXCAVATION TO BE MIN. 4" LARGER THAN PRECAST BOX ON ALL SIDES. BACKFILL WITH CLASS 100-E-100 PCC.

TITLE: **DROP INLET (24"x36")**

DRAWN BY: STAFF  
 SCALE: NONE  
 REVIEWED BY: DANNY HILLSTOCK  
 REVISED: OCTOBER, 2019  
 CITY OF HOLLISTER  
 ENGINEERING DEPARTMENT

APPROVED:  
*Danny Hillstock* 11-5-19  
 CITY ENGINEER: DANNY HILLSTOCK LIC. NO. 70647 DATE

STANDARD PLAN  
**D-3-4**  
 SHEET 4 OF 4