



# City of Hollister Development Services Building Division

339 Fifth Street, Hollister, CA 95023 \* Ph. (831) 636-4355 \* Fax. (831)634-4913

---


## Kitchen Remodel Requirements

1. Kitchen doors leading from the garage shall be 1-3/8 inch thick solid wood, honeycomb core steel doors, or 20 minute fire-rated doors equipped with self-closing and self-latching devices. (CRC R302.5.1)
2. All installed luminaries shall be high efficacy. (CEC (k)(1)(A))
3. Household cooking appliances shall have a vertical clearance above the cooking top of not less than thirty (30) inches to combustible material or metal cabinets. (CMC 920.3.2)
4. Exhaust ducts shall terminate outside the building and shall be equipped with a backdraft damper per CMC Section 504.1.
5. All receptacles shall be Arc Fault Circuit Interrupter (AFCI), Ground Fault Circuit Interrupter (GFCI) protected, and Tamper-Resistant (TR).
6. Receptacles along the countertop shall be located so that no point is more than 24 inches from a receptacle outlet measured horizontally along the wall. CEC 210.52 (A)
7. Receptacles shall be located no more than 20 inches above the countertop. **(See illustration)**
8. Dishwashers, garbage disposals, insta-hots, compactors, built in microwave ovens, and the kitchen lighting shall be on dedicated electrical circuits.
9. Island or peninsulas require at least one receptacle. The receptacles may not be more than 12" below the counter surface or be below a counter that extends more than 6" beyond a cabinets end point. When an interruption in a countertop surface occurs on an island, a receptacle shall be installed on each side of the sink or appliance.
10. The maximum length for a garbage disposal cord is 36 inches and a dishwasher is 48 inches. Both receptacles must be accessible, with the dishwasher outlet located in the space adjacent to the dishwasher. CEC 422.16(B)(2)(6)
11. The countertop circuits may only be shared with the dining room or a pantry.
12. On the discharge side of the dishwasher, provide a listed air gap fitting. Listed air gaps shall be installed with the flood level (FL) marking at or above the flood level of the sink or drain board whichever is higher. (CPC 807.3)
13. Kitchens shall have a clear passageway of not less than 3 feet between counter fronts and appliances or counter fronts and walls.
14. Insulation is required to be installed in all walls, floors and ceilings open for construction between conditioned space and unconditioned space, such as exteriors, garages, crawl spaces and attics. Type of insulation required: Walls: 2x4 R-13 or 2x6 R-19; Ceiling and Floor R-19.
15. All oven and stove gas valves shall be accessible and be within 6-feet of the appliance. Shutoff valves shall be permitted to be accessibly located inside, behind, or under an appliance where the appliance is removed without removal or damage of the shutoff valve.

FIG. 30

### Kitchen Receptacles

Cord-plug connected range-hood allowed if supplied by individual branch circuit.



Max. 12 in. from countertop

Max. 6 in. overhang above receptacle

Island or peninsula countertop spaces req. only 1 receptacle—2-ft./4-ft. rule does not apply.

FIG. 31

### 2-ft./4-ft. Rule

Wall countertop receptacles serve the spaces for 2 ft. on each side of the receptacle. Therefore, the maximum spacing between receptacles on the same countertop space is 4 ft.

